

Wind turbine switchgear safety

– a concise guide
May 2010





Acknowledgements

RenewableUK acknowledges the time, effort, experience and expertise of all those who contributed to this document. Details of the organisations who participated in the consultation and editorial of this document are available on request from RenewableUK.

Disclaimer

The contents of this guide are intended for information and general guidance only, do not constitute advice, are not exhaustive and do not indicate any specific course of action. Detailed professional advice should be obtained before taking or refraining from action in relation to any of the contents of this guide, or the relevance or applicability of the information herein.

Introduction

Properly designed, installed and maintained switchgear is a vital prerequisite for any safe, secure and successful wind turbine installation. This guidance is primarily aimed at designers, developers, operators and owners of wind turbines that may incorporate switchgear with voltage ratings >1000 volts alternating current (AC). It is intended as a basic overview of the key issues and arrangements for preventing and managing electrical risks associated with currently installed and new switchgear. The guidance only applies to switchgear subject to the jurisdiction of UK Health and Safety legislation.

The information in this document should only be regarded as generic advice. It represents industry good practice for switchgear safety operated on UK operational wind farms and arrays ('the industry'). It does not aim to address general safety issues for switchgear for which there is already an extensive range of standards and guidance in the public domain. In addition, site, location, turbine and switchgear specific assessments must still be performed to determine the most effective approach to managing switchgear.

This guide aims to set out the:

- critical safety issues with particular consideration of the specification of switchgear and competence issues;
- legislation, standards and policies relevant to switchgear;
- measures to consider in the management of existing switchgear;
- measures to take into account when determining the suitability of new switchgear; and
- additional advice representing good practice based on operational experiences in the UK.

Critical safety issues

All electrical switchgear must be considered a potentially serious safety risk. The principal risks associated with switchgear include electrocution, burns, explosions and fire. The failure to manage these can lead to death or serious injury. A major switchgear failure could also have consequential impacts including criminal liability, contractual/warranty claims, business continuity and/or damage to corporate reputation.

The Health and Safety Executive (HSE) has identified a number of common failure modes associated with the operation of switchgear. These include failures relating to a lack of knowledge, modifications, maintenance and anti-reflex handles. This guide does not consider these in detail as the issues are already clearly set out in HSE guidance and associated switchgear standards (see references).

To date there is insufficient evidence or data detailing any common safety trends across the industry for switchgear. However the risk of safety failures will increase where there is a poor understanding of the operational interface between the selected switchgear, the specific site/turbine operational arrangements and the network. In addition, two key issues have been identified of particular relevance to the industry with regard to the safe use of switchgear. These relate to the specification of the equipment and the competence of personnel operating on or adjacent to switchgear.

Specification

Understanding and achieving the correct specification of switchgear that is suitable and safe for the specific operational circumstances of the installation is vital. Examples of how this can be achieved include:

- ensuring switchgear is suitable for the particular environment on the wind farm/array, turbine or enclosure;

- ensuring the switchgear is suitable for the installed location taking account of working space and access for operation and maintenance;
- performing relevant testing that is appropriate for the specific location/application and ensuring that there are adequate risk-based procedures in place to support the correct use of switchgear;
- ensuring there are robust access control procedures for competent personnel in place, which are specific to the classification of the turbine or enclosure when operated as a sub-station;
- aiming to prevent and minimise risks through access prevention and the use of remote operational techniques;
- providing adequate provision for arc venting and dissipating energy during a fault condition within the area/enclosure in which the HV switchgear is located;
- agreeing and applying common standards for labelling and the annotation of electrical and mechanical diagrams; and
- agreeing and applying common standards for warnings and warning notices.

Competence

Anyone working on or adjacent to switchgear must be competent. Determining the level of competence required, needs to consider both the organisational arrangements and the individual capabilities of anyone working on or around switchgear. These together must be risk assessed taking into account the specific operational circumstances of the installation. Examples of competence issues to consider include:

- understating the need to determine and apply a multiple-level approach to assigning and achieving competence (e.g. basic awareness to fully authorised);
- segregating equipment and personnel that reflect competence levels; and
- using suitable mechanical protection measures to prevent and minimise human error (e.g. anti-reflex handles, interlocking devices, physical controls, barriers, PPE etc.).

It should also be stated that consideration should also be given to the competence of anyone involved in the procurement, installation and commissioning of switchgear. Further, clients need to consider the issue of competence when engaging any contractor or third party involved with switchgear.

Legislation, standards and policies

Legislation

The principal legislation relevant to the selection and use of switchgear operated in the UK includes the:

- Health and Safety at Work etc. Act 1974 ('HSW') – places duties on employers to ensure the safety of employees and others so far as reasonably practicable. Duties also extend to designers, manufacturers, importers or suppliers of any article for use at work;
- Management of Health and Safety at Work Regulations 1999 – absolute duty to carry out suitable and sufficient risk assessments;
- Electricity at Work Regulations 1989 - require electrical equipment for use at work to be constructed, maintained and operated in such a way as to prevent danger so far as is reasonably practicable; and
- Electricity Safety, Quality and Continuity Regulations 2002 – apply to electricity generation, generators, networks, suppliers and distributors regarding aspects of supply and distribution.

It should also be noted that the Health and Safety at Work etc. Act 1974 (Application outside Great Britain) (Variation) Order 2009 has now extended the prescribed provisions of the HSW Act to work activities beyond the territorial sea and to other specified areas designated by order under section 1(7) of the Continental Shelf

Act 1964. It extends the HSW Act to work activities such as the construction, repair and operation of energy structures and related structures within a renewable energy zone (REZ).

This legislation listed above is far from exhaustive. Duty holders will also need to review the significance of other legislation which may be relevant to the selection, installation, commissioning and use of switchgear (e.g. Construction Design and Management Regulations 2007 ('CDM 2007')). See the references, and contact and links sections below for more details.

The principal duty holder for the determination of suitability of the switchgear will normally reside with the designer of the system. They will be responsible for the integration of the specific switchgear and allied equipment into the particular network. Clients are recommended to request a copy of the design risk assessment to demonstrate a robust process has validated that the design is safe.

Standards

There are a number of potential BS/EN or equivalent standards that apply to switchgear. The most relevant standards are:

- EN 62271-200:2004 – High-voltage switchgear and control gear – Part 200: AC metal-enclosed switchgear and control gear for rated voltages above 1kV and up to and including 52kV;
- BS 6626:1985 Code of practice for maintenance of electrical switchgear and control gear for voltages above 11kV and up to and including 36kV;
- ENA Technical Specification (TS) 41-36 Issue 2 2004: Distribution Switchgear for Service up to 36kV (cable and overhead cable connected); and
- ENA Technical Specification (TS) 41-37 Issue 2 2004: Distribution Switchgear for Service up to 66kV–132kV.

Further examples are detailed in the references.

The HSE has stated that full compliance with EN 62271-200:2004 is considered the minimum acceptable standard for switchgear in the UK. They have further indicated that there is an obligation to upgrade any equipment to be compliant with this standard. It is regarded as good industry practice for switchgear to endeavour to meet the design safety and operational requirements of ENA TS 41-36 or TS 41-37. Certification to ENA standards is regarded as an optional protocol that duty holders may choose to perform to demonstrate additional confidence in assurance arrangements.

Note: standards have no stand-alone legal status. However, an enforcing authority or court may apply and recognise standards as evidence of good practice in applying the principle of ALARP (as low as reasonably practicable) to a particular risk or activity.

Policies and procedures

Anyone responsible for existing and new switchgear should have suitable arrangements in place to ensure the safe operation of switchgear to minimise the risk of injury. As a minimum this would include:

- policies and procedures covering the design, specification, installation, commissioning, operation, maintenance, modifications and decommissioning of the equipment;
- an appropriate system of records and document control;
- definition of responsibilities, training and competence requirements; and
- audit and review of protocols to demonstrate the effectiveness of procedures.

These represent nothing more than what would be regarded as minimum industry practice, but are nonetheless

important to reiterate in view of safety risks concerned. These arrangements can be incorporated into existing Health and Safety management systems, including those required under statute and/or voluntary schemes. Note: some duty holders in the UK have found through operational experience that safety standards can be more effectively controlled when operated as a separate management system.

Existing switchgear

All switchgear users should determine what arrangements are necessary by conducting appropriate risk assessments with the support of suitable electrically competent personnel. Specific issues identified as good practice for equipment utilised in the UK include:

- drawing up an asset register detailing site and equipment-specific technical information and recording this in a suitable format;
- checking any safety non-compliances against the minimum electrical safety standards and, where applicable, with any specification or technical standards agreed;
- provision of adequate High Voltage (HV) safety rules suitable for the operational risks;
- taking into account location-specific safety issues, including consideration of spacing, environmental conditions (e.g. temperature), security and access; and
- robust procedures and rules to provide a safe system of work (SSW) covering working dead and earthed, using authorised competent persons and controlling access.

Although of a more general nature it is important to reiterate other areas that may need to be addressed. These could include:

- carrying out a planned programme of upgrading or retrofitting suitable controls where safety shortfalls have been identified;
- reviewing the need for authorised persons and others to undergo refresher training;
- updating policies and procedures taking account of any new information, installed controls or safe systems of work;
- ensuring all changes are recorded and communicated to employees, contractors and others who may be at risk;
- conducting a planned programme of inspection and maintenance; and
- performing periodic auditing of procedures and controls to ensure the safety and integrity of the switchgear.

New switchgear

The principal duty holder responsible for determining the suitability of switchgear is the designer. This could also include the clients where their decisions influence the final design or specification. Because of the variety of routes to market all parties concerned with the design and specification of switchgear should fully cooperate and communicate with each other. This should include clarification of their particular role and responsibilities for the project concerned.

A prudent client and CDM-C (as defined under CDM 2007) are recommended to consider:

- having a suitable procurement policy setting out the relevant design, technical and operational safety requirements for the project;
- early communication with original equipment manufacturers ('OEMs') and switchgear manufacturers to allow the opportunity to consider relevant safety issues; and
- agreeing the selection criteria for the switchgear, taking account of design features, applicable standards and statutory requirements.

Specifically this should include requesting a copy of the design risk assessment to demonstrate a robust process has validated the design.

The location of switchgear should be assessed from a safety perspective. The HSE has stated that from a safety point of view switchgear should be located in a separate building. Where this is not practicable due to planning or other restrictions, suitable precautions should be taken to restrict access to switchgear from unauthorised personnel.

Additional advice

Experience within the UK gained in recent years has identified a number of practical measures that can be taken to ensure HV switchgear installed is safe for anyone working on or adjacent to it. The principal examples include:

1. **Competence:** Turbines containing HV equipment are considered as sub-stations. It is a legal requirement that minimum levels of competence are determined for access. This should cover simple access for tasks inside a turbine to working on the HV system.
2. **Anti-reflex handles:** It is commonly accepted that anti-reflex handles are the minimum level of equipment provision for switchgear in the UK. It is necessary that designers consider the provision of either proprietary bespoke handles or, with the agreement of the manufacturer, to retrofit suitable handles to the equipment.
3. **Labelling:** Many electrical incidents are due to poor labelling and information. All equipment must be clearly and accurately labelled. This will often include the production of mimic diagrams. Statutory warning signs for sub-stations need to be provided.
4. **Location:** Switchgear should ideally be located in a separate building. If this is not practicable due to planning or other restrictions, suitable precautions should be taken to restrict access to switchgear from unauthorised personnel.
5. **Environment:** Generally, switchgear used in this application is classed as indoor equipment and reference is made to the required normal service conditions given in IEC62271-1 sub-clause 2.1.1. The design should ensure that the equipment specification is suitable for both the intended location and the actual location of switchgear. The overriding principle is therefore to ensure that either the switchgear is made to a standard that suits the installation OR the installation is designed to suit the constraints of the switchgear.
6. **Isolation and earthing:** Procedures to ensure effective electrical isolation and earthing are essential. Turning off an electrical supply will not make the system safe. Steps must be taken to prevent re-energisation.
7. **Maintenance:** No equipment is maintenance free. A suitable and comprehensive maintenance programme for the equipment should be implemented to cover the operational life of the equipment.
8. **Electrical protection:** Records should be maintained for any installed protection relays. This should include details of the protection scheme design, protection settings applied and the calculations used to demonstrate the settings are adequate.
9. **Interlocking:** These systems provide a safe environment to operate switchgear and are included to mitigate against operator error. For example, interlocking systems can provide an effective method of preventing access to a live transformer by only allowing access when the transformer is isolated and earthed. Interlocking is provided by both mechanical and electrical means.
10. **Remote operation:** Internal switchgear failures can result in an explosive release of energy. Specific consideration should be given to using suitable remote switching, umbilical or lanyard devices, to minimise the risks to operators. This could extend to the use of supervisory control and data acquisition (SCADA) techniques to facilitate remote testing and inspection.
11. **Records:** Clear, accurate and up-to-date records are essential. These must be easily available to all persons working on switchgear. This would normally include records detailing operational diagrams and the electrical arrangements of the switchgear (e.g. circuit breakers, earth switches), switchgear rating plate information and serial numbers, electrical schematics and wiring diagrams, and commissioning

records. This information must interface with maintenance data in order to respond to product defect notices and identify any serial defects in the equipment.

12. Proving dead: It is a statutory requirement in the UK to prove dead at the point of work before working on electrical equipment. Test points on the switchgear may allow this testing, depending on the design. If they are not available testing can prove difficult or dangerous and an approved written procedure must be adopted to prove the switchgear is dead. Precautions should be taken to avoid any sole reliance on capacitive coupled voltage presence indicators/test points as proof of disconnection.

Reference sources

The following references are only intended as an indicative summary.

HSE

- HSG 85 Electricity at Work Safe Working Practices – Electrical Switchgear and Safety: a concise guide for users
- Safety in electrical testing at work: general guidance
- Safety in electrical testing: switchgear and control gear. Engineering Information Sheet 37
- HSG 230 Keeping Electrical Switchgear Safe
- Memorandum of Guidance on the Electricity at Work Regulations 1989

BSI

- BS EN 50308:2004 Wind Turbines – Protective measures – requirements for design, operation and maintenance
- BS EN 61400-1:2005 Wind turbines – Design requirements
- BS EN 61400-3:2009 Wind Turbines –Design requirements for offshore wind turbines
- BS 6626:1985 Code of practice for maintenance of electrical switchgear and control gear for voltages above 1kV and up to and including 36kV
- BS EN 62271-1:2008 High-voltage switchgear and control gear – Common specifications

CEN

- EN 62271-200:2004 – High-voltage switchgear and control gear – Part 200: AC metal-enclosed switchgear and control gear for rated voltages above 1kV and up to and including 52kV

IEC

- IEC 62271-200: 2003 – High-voltage switchgear and control gear – Part 200: AC metal-enclosed switchgear and control gear for rated voltages above 1kV and up to and including 52kV

EC

- Low Voltage Directive – 2006/95/EC
- Machinery Directive – 2006/42/EC

ENA

- Technical Specification (TS) 41-36 Issue 2 2004: Distribution Switchgear for Service up to 36kV (cable and overhead cable connected)
- Technical Specification (TS) 41-37 Issue 2 2004: Distribution Switchgear for Service up to 66kV–132kV

RenewableUK

- Health and Safety Guidelines 2010 (awaiting publication)

NOTE: There are numerous additional references that may be relevant to switchgear safety. The majority are likely to be available via the contacts and links below.

Contacts and links

- British Electrotechnical and Allied Manufacturers Association (BEAMA) <http://www.beama.org.uk/>
- British Standards Institute (BSI) <http://www.bsi-global.com/>
- Energy Network Association (ENA) <http://2009.energynetworks.org/>
- Health and Safety Executive (HSE) <http://www.hse.gov.uk/>
- European Committee for Standardization <http://www.cen.eu/cenorm/homepage.htm>
- European Community (EC) Directives <http://eur-lex.europa.eu/en/index.htm>
- The Institution of Engineering and Technology (IET) <http://www.theiet.org/>
- International Electrotechnical Commission (IEC) <http://www.iec.ch/>
- RenewableUK <http://www.renewable-uk.com>
- OPSI <http://www.opsi.gov.uk/>